

STD- 07184, Office - 255093, C.O - 252088, President - 251720

OFFICE OF THE MUNICIPAL COUNCIL, BHANDARA.

No. - MCB/CO/9/34 /2022

Email- bhandaranagarpalika@gmail.com

Date: - 9

/2022

FIRE SAFETY CERTIFICATE

Colony, Bye Pass Road, Bhandara Dist-Bhandara. Comprised of Ground floor occupied by Lord's Public School, run by Udayan Bahuudheshiya Vikas Sanstha, Bhandara, have completed with the fire prevention and fire safety requirements in accordance with Fire Safety rule of Maharashtra Fire Safety Regulation, 2006 and verified by the officer concerned of Fire Service on 09/05/2022 in the presence of Manager Mr. Rajesh Jagnik, R/O. Khat Road, Bhandaraof Lord's Public School, Bhandara and that the said school premises is fit for the occupancy up to classes X. With effect from 09/05/2022 to 08/05/2023 for a period of One Year in accordance with rule & subject to compliance of specific conditions as appended:

- 1) School has instructed to get all the fire safety equipments inspected through licensed agency in every six month i.e. January to June and get Form B from Licensed agency. One copy of which has to be submitted mandatorily to the Municipal Council, Bhandara.
- 2) According to the Maharashtra Fire Prevention and Lifesaving Act 2006 it is mandatory to not install fire hydrant and sprinkler with alarm system.
- 3) Fire extinguishers equipments BC (Co2) of 4.5 kg of 01 number & ABC (DCP) of 6 kg in 09 numbers were installed and these are valid till 08/05/2023.

4) It is also certified that Old Fire Extinguishers Equipments Servicing, Refilling, Maintenance are in good Conditions to run the School.

Note: The Fire Department of Bhandara District comes under Municipal Council Bhandara and Signatory Authority is Chief Officer Municipal Council, Bhandara

(Vinod Jadhao)

Chief Officer

Municipal Council, Bhandara.

Manager
The Lords Public School,
Bhandara-441904

Tool A Control of the Control of the

Principal
The Lord's Public School,
Bhandara.